

BATHROOM ACCESSIBILITY CHECKLIST

SIGNAGE

- ☐ Are there tactile signs at inaccessible restrooms giving directions to an accessible restroom?
- ☐ Is there a tactile sign identifying an accessible restroom?

DOORWAYS AND PASSAGES

- ☐ Is the door handle to the restroom 48" high or less and openable with a clenched fist?
- ☐ Is there a 5' circle free around the door?
- ☐ Is the door at least 32" wide?
- ☐ Is the door openable easily (with a maximum of 5 lbs. of pressure)?
- ☐ Alternatively, is a power door open for at least 3 seconds?
- ☐ Is there a minimum of 36" of clear width forward from the door?
- ☐ Is there a path a minimum of 36" wide to all fixtures?

BATHROOM ACCESSIBILITY CHECKLIST

STALLS

- ☐ Is there a wheelchair accessible stall that has an area of at least 5' by 5' clear of the door swing?
- ☐ Can the stall doors be opened with a clenched fist inside and out?
- ☐ Are there grab bars behind and on the wall nearest the toilet with a 1 ½" grab bar clearance?
- ☐ Is the toilet seat high enough (17" – 19" high)?

LAVATORIES

- ☐ Is there a 30" by 48" space clear in front of the sink?
- ☐ Is the sink rim no higher than 34" high, yet allow 27" for knee clearance?
- ☐ Are the drain pipes or water lines covered?
- ☐ Can the sink faucets be opened with a closed fist?
- ☐ Is the soap dispenser within reach, and can it be operated with a clenched fist?
- ☐ Is there a mirror with the bottom edge of the reflecting surface no higher than 40"?

BATHROOM ACCESSIBILITY CHECKLIST

DRINKING FOUNTAINS

- ☐ Does the drinking fountain have a clear floor space at least 30" by 48" in front?
- ☐ Is there a spout no higher than 36" from the ground?
- ☐ Are fountain controls mounted on the front or on the side near the front edge and operable with one closed fist?
- ☐ Is the fountain cane-detectable (within 27" of the floor or protruding less than 4" from the wall)?